

## Don & Low Ltd Nonwovens

Glamis Road  
Forfar  
Angus DD8 1EY  
Tel: 01307 452600 Fax: 01307 452610  
e-mail: nonwovens@donlow.co.uk  
website: www.donlow.com



Agrément Certificate  
**03/4003**  
Product Sheet 2

### BREATHABLE DALTEX ROOFTX MEMBRANES

### ROOF TILE UNDERLAY FOR USE IN COLD NON-VENTILATED ROOFS

#### PRODUCT SCOPE AND SUMMARY OF CERTIFICATE

This Certificate relates to Breathable Daltex RoofTX Membranes, roof tile underlays for use in cold non-ventilated pitched roof systems.

#### AGRÉMENT CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.

#### KEY FACTORS ASSESSED

**Weathertightness** — as part of a complete roof, the products will resist the passage of water and wind-blown snow and dust into the interior of the building (see section 5).

**Risk of condensation** — the products are low water vapour resistance (Type LR) underlays and can be used as part of a cold non-ventilated pitched roof system without specific provisions for ventilation (see section 6).

**Wind loading** — when installed on appropriately spaced battens, the products' physical properties are deemed adequate to resist the wind loads imposed on the underlay. The products will reduce the wind uplift forces acting on the roof covering (see section 7).

**Strength** — the products have adequate strength to resist the loads associated with the installation of the roof (see section 8).

**Durability** — under the normal conditions found in a roof space the products will have a service life comparable to a traditional roof tile underlay (see section 11).



The BBA has awarded this Agrément Certificate to the company named above for the products described herein. These products have been assessed by the BBA as being fit for their intended use provided they are installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Stuart Sadler  
Head of Approvals — Materials

Greg Cooper  
Chief Executive

Date of Fifth issue: 8 April 2011

Originally certificated on 4 June 2007

*The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at [www.bbacerts.co.uk](http://www.bbacerts.co.uk)*

*Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.*

British Board of Agrément  
Bucknalls Lane  
Garston, Watford  
Herts WD25 9BA

tel: 01923 665300  
fax: 01923 665301  
e-mail: [mail@bba.star.co.uk](mailto:mail@bba.star.co.uk)  
website: [www.bbacerts.co.uk](http://www.bbacerts.co.uk)

©2011

# Regulations

In the opinion of the BBA, Breathable Daltex RoofTX Membranes, if used in accordance with the provisions of this Certificate, will meet or contribute to meeting the relevant requirements of the following Building Regulations:



## The Building Regulations 2010 (England and Wales)

<b>Requirement:</b> C2(b)	<b>Resistance to moisture</b>
<b>Comment:</b>	The products will contribute to a roof meeting this Requirement. See section 5.1 of this Certificate.
<b>Requirement:</b> C2(c)	<b>Resistance to moisture</b>
<b>Comment:</b>	The products will contribute to a roof to meet this Requirement with respect to interstitial condensation. See sections 6.1 to 6.6 of this Certificate.
<b>Requirement:</b> Regulation 7	<b>Materials and workmanship</b>
<b>Comment:</b>	The products are acceptable. See section 11 and the <i>Installation</i> part of this Certificate.



## The Building (Scotland) Regulations 2004 (as amended)

<b>Regulation:</b> 8(1)	<b>Fitness and durability of materials and workmanship</b>
<b>Comment:</b>	The use of the products satisfies this Regulation. See section 11 and the <i>Installation</i> part of this Certificate.
<b>Regulation:</b> 9	<b>Building standards – construction</b>
<b>Standard:</b> 3.10	<b>Precipitation</b>
<b>Comment:</b>	The products will contribute to a roof satisfying clauses 3.10.1 <sup>(1)(2)</sup> and 3.10.7 <sup>(1)(2)</sup> of this Standard. See section 5.1 of this Certificate.
<b>Standard:</b> 3.15	<b>Condensation</b>
<b>Comment:</b>	The products can contribute to a roof satisfying this Standard with respect to interstitial condensation. See sections 6.1 to 6.6 of this Certificate.
<b>Regulation:</b> 12	<b>Building standards – conversions</b>
<b>Comment:</b>	All comments given for these products under Regulation 9, also apply to this Regulation, with reference to clause 0.12.1 <sup>(1)(2)</sup> and Schedule 6 <sup>(1)(2)</sup> . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).



## The Building Regulations (Northern Ireland) 2000 (as amended)

<b>Regulation:</b> B2	<b>Fitness of materials and workmanship</b>
<b>Comment:</b>	The products are acceptable. See section 11 and the <i>Installation</i> part of this Certificate.
<b>Regulation:</b> C4(b)	<b>Resistance to ground moisture and weather</b>
<b>Comment:</b>	The products will contribute to a roof satisfying this Regulation. See section 5.1 of this Certificate.
<b>Regulation:</b> C5	<b>Condensation</b>
<b>Comment:</b>	The products can contribute to a roof satisfying this Regulation. See sections 6.1 to 6.6 of this Certificate.

## Construction (Design and Management) Regulations 2007

## Construction (Design and Management) Regulations (Northern Ireland) 2007

Information in this Certificate may assist the client, CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

See section: 1 *Description* (1.2) of this Certificate.

# Non-regulatory Information

## NHBC Standards 2011

The use of Breathable Daltex RoofTX Membranes, in cold non-ventilated roofs is not permitted under the requirements of these Standards.

# General

Daltex RoofTX is a registered trademark of Don & Low Ltd Nonwovens.

# Technical Specification

## 1 Description

1.1 Breathable Daltex RoofTX Membranes are composite structures, manufactured via lamination of a water vapour permeable film between two layers of nonwoven polypropylene, spunbond to form a flexible, vapour permeable, roof tile underlay for unsupported and fully supported specifications.

1.2 The products have the nominal characteristics given in Table 1.

Table 1 Nominal characteristics

Characteristic (units)	Daltex RoofTX Optima <sup>(1)</sup>	Daltex RoofTX Ultra <sup>(1)</sup>	Daltex RoofTX	Daltex RoofTX Maxi <sup>(2)</sup>	Daltex RoofTX Extra <sup>(2)</sup>
Thickness (mm)	0.35	0.40	0.50	0.60	0.75
Weight per unit area (g·m <sup>-2</sup> )	92	112	125	165	208
Roll length (m)	50	50	50	50	50
Roll width (m)	1.0/1.5	1.0/1.5	1.0/1.5	1.0/1.5	1.0/1.5
Roll weight (kg)					
minimum	5	6	7	9	11
maximum	7	9	10	13	16
Colour					
upper	various	various	various	various	various
lower	various	various	various	various	various

(1) Subject of BBA Certificate 06/4334, Product Sheet 2.

(2) Subject of BBA Certificate 05/4209, Product Sheet 2.

1.3 Quality control checks are carried out on the incoming materials, during production and on the finished products.

## 2 Delivery and site handling

2.1 Rolls are delivered to site individually wrapped in polythene. A technical leaflet bearing the product name is included with each roll and the BBA identification mark including the number of this Certificate is shown on the leaflet.

2.2 The rolls should be stored flat or on end, on a smooth, clean, dry surface, under cover and protected from sunlight.

# Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Breathable Daltex RoofTX Membranes.

## Design Considerations

### 3 Use

3.1 Breathable Daltex RoofTX Membranes are satisfactory for use in dwellings with non-ventilated tiled or slated roofs of any conventional plan and of any size. Features<sup>(1)</sup> successfully assessed include:

- duo pitched
- gable ends
- room-in-the-roof<sup>(2)</sup>
- mono-pitched
- verges
- dormers
- hipped
- abutments
- timber sarking<sup>(3)</sup>
- mansard
- valleys.

(1) For roofs incorporating other features, non-conventional roof geometries or construction materials, the advice of the Certificate holder should be sought.

(2) Where a room-in-the-roof results in part of a roof pitch being insulated (ie a warm roof), design and detailing of that part of the roof should comply with relevant guidance given in Product Sheet 1.

(3) As in Scottish practice, where slates are nailed through the breather membrane directly onto timber planks (nominally 150 mm wide with a 2 mm gap) without battens.

3.2 It is important that the designers, planners, contractors and/or installers ensure that the roof and ceiling are constructed in accordance with the Certificate holder's instructions and the information given in this Certificate.

3.3 The products can be installed by draping over rafters and securing with tiling battens, or installed taut over rafters and secured with counter battens and tiling battens, or supported over uninsulated timber plank sarking.

3.4 In conventionally-ventilated roof constructions, energy loss by ventilation can account for up to 25% of the total heat lost through the roof. The non-ventilated system will substantially reduce this mechanism of heat loss.

3.5 In non-ventilated roof systems, the risk of condensation is equivalent to, or less than, that for conventionally ventilated cold roof systems (see section 6).

### 4 Practicability of installation

The products can be installed by roofers experienced with this type of product.

## 5 Weathertightness



5.1 Tests indicate that the products will resist the passage of water, wind-blown snow and dust into the interior of a building, under all conditions to be found in a roof constructed in accordance with the relevant Clauses of BS 5534 : 2003.

5.2 The products resist penetration of liquid water and consequently may be used as temporary waterproofing prior to the installation of slates or tiles. The period of such use should, however, be kept to a minimum. See BBA Information Bulletin No 2 — *Permeable Roof Tile Underlay – Guide to Good Site Practice* and see section 16 of this Certificate, Table for *Physical properties – general*.

## 6 Risk of condensation



6.1 For design purposes, the products' water vapour resistance may be taken as not more than  $0.25 \text{ MN}\cdot\text{s}\cdot\text{g}^{-1}$ , and for roofs designed in accordance with BS 5534 : 2003 or BS 5250 : 2002, Section 8.4, it may be regarded as a Type LR membrane.

6.2 The complete roof construction, ceiling boards to roof tiles, must be considered as a total system with regard to condensation risk. It is important that the products are laid in accordance with the Certificate holder's instructions and this Certificate to minimise the risk of condensation.

6.3 The risk of condensation is highest in new-build construction during the first heating period, where there is high moisture loading due to wet trades, such as in-situ cast concrete slabs or plaster. The risk of condensation diminishes as the building naturally dries out. See BBA Information Bulletin No 1 — *Roof Tile Underlays in Cold Roofs during the Drying-out Period*.

6.4 All penetrations into and out of the roof space must be properly sealed in accordance with the Certificate holder's instructions which includes the use of the Certificate holder's recommended sealing tape. In addition, such features as vent stacks and boiler flues, passing through the roof space must be sealed.

6.5 It is essential to minimise water vapour transfer into the loft space from the dwelling below. Appropriate measures include:

- ventilating the dwelling below in accordance with national Building Regulations and Standards for the dispersal and rapid dilution of water vapour, particularly from rooms that may experience high humidity (such as kitchens, utility rooms and bathrooms)
- covering all water tanks in the loft space and lagging pipework
- sealing penetrations in the ceiling and making loft hatches convection-tight by using a compressible draught seal
- ensuring that there is continuity of jointing with walls (and behind wall linings) at ceiling perimeters
- ensuring that masonry wall cavities do not interconnect with roof cavities.

6.6 For additional protection, the use of a vapour control layer/vapour check plasterboard can be considered.

## 7 Wind loading

7.1 Project design wind speeds should be determined and wind uplift forces calculated, in accordance with BS EN 1991-1-4 : 2005 and the UK National Annex.

7.2 The products, when fully supported by uninsulated timber plank sarking, have adequate resistance to wind uplift forces.

7.3 When unsupported, wind loading on the underlay should be calculated in accordance with BS 5534 : 2003, Section 5.5.2.7. For acceptable wind loads with specific batten spacings for the draped product, using a 25 mm deep tiling batten see section 16, Table for *Physical properties – general*.

## 8 Strength

The products will resist the normal loads associated with installation of the roof.

## 9 Properties in relation to fire

9.1 The products will have similar properties in relation to fire to those of traditional polyethylene roof tile underlays.

9.2 When the products are used unsupported, there is a risk that fire can spread if the materials are accidentally ignited during maintenance works, eg by a roofer's or plumber's torch. As with all types of underlay, care should be taken during building and maintenance to avoid the material becoming ignited.

9.3 When the products are used in a fully supported situation, the fire performance will be determined by the support.

9.4 The products achieve a Class D classification in accordance with BS EN 13501-1 : 2002.

## 10 Maintenance

As the products are confined to the roof space and have suitable durability, maintenance is not required. However, it must be ensured that damage occurring before enclosure is repaired (see section 14).

## 11 Durability



The products will be virtually unaffected by the normal conditions found in a roof space and will have a life comparable with that of traditional roof tile underlays, provided they are not exposed to sunlight for long periods (see section 12.5). Advice regarding exposure can be obtained from the Certificate holder.

## Installation

### 12 General

12.1 Breathable Daltex RoofTX Membranes must be installed and fixed in accordance with the Certificate holder's instructions, provisions of this Certificate and the relevant recommendations of BS 5534 : 2003 and BS 8000-6 : 1990. Installation can be carried out under all conditions normal to roofing work.

12.2 The products have a high coefficient of friction, either wet or dry, giving a slip-resistant surface for increased safety during the installation of the tiles or slates.

12.3 The products are installed with the coloured or printed side uppermost and lapped to shed water out and down the slope.

12.4 Overlaps must be provided with the minimum dimensions given in Table 2.

12.5 Where possible, eaves guards should be used to protect the product from sunlight and direct water into the gutter.

Table 2 Minimum overlaps

Roof pitch (°)	Horizontal lap (mm)		Vertical laps (mm)
	Not fully supported	Fully supported	
12.5 to 14	225	150	100
15 to 34	150	100	100
35+	100	75	100

### 13 Procedure

#### Draped and loose laps

13.1 The product should be installed as an unsupported system, and fixed in the traditional method for roof tile underlays, ie draped between rafters, with the coloured printed side uppermost.

#### Timber plank sarking

13.2 For fully supported roofs (traditional Scottish), the slates can be nailed through the product into the timber plank sarking, normally 150 mm wide with a 2 mm gap.

### 14 Repair

Damage to the products can be repaired prior to the installation of slates or tiles by replacement of the damaged areas, by patching and sealing correctly. Care should be taken to ensure that the watertightness of the roof is maintained.

### 15 Finishing

15.1 Detailing of abutments, verges and hips must be in accordance with the Certificate holder's instructions.

15.2 To achieve a convection-tight loft space, it is important that the following details are maintained (see also sections 6.4 and 6.5).

- all penetrations, eg pipework, electrical fittings to the loft space, must be sealed
- the loft hatch must be securely sealed to ensure a draught-free fit
- the insulation must be pushed into the eaves and against the underlay to avoid gaps.

15.3 The tiling and slating must be carried out in accordance with the relevant Clauses of BS 5534 : 2003, BS 8000-6 : 1990 and the Certificate holder's instructions, especially when using tightly-jointed slates or tiles.

## Technical Investigations

### 16 Tests

Samples of Breathable Daltex RoofTX Membranes were obtained from the Certificate holder for testing. The results of the tests carried out by, or on behalf of, the BBA are summarised in Tables 3 and 4

**Table 3 Physical properties — directional**

Test (units)	Mean result					Method
	Daltex RoofTX Optima	Daltex RoofTX Ultra	Daltex RoofTX	Daltex RoofTX Maxi	Daltex RoofTX Extra	
Tensile strength (N per 50 mm)						BS EN 12311-1
unaged						
longitudinal	261	268	270	318	490	
transverse	134	138	150	189	310	
aged <sup>(1)</sup>						
longitudinal	197	205	200	286	415	
transverse	102	108	115	166	319	
Elongation at break (%)						BS EN 12311-1
unaged						
longitudinal	73	54	43	31	15	
transverse	86	62	57	43	13	
aged <sup>(1)</sup>						
longitudinal	34	30	26	22	14	
transverse	43	37	36	28	12	
Tear resistance (nail) (N)						BS EN 12310-1
unaged						
longitudinal	109	126	152	324	405	
transverse	63	93	196	211	315	

(1) UVA aged for 336 hrs at 50°C/heat aged for 90 days at 70±2°C.

**Table 4 Physical properties — general**

Test (units)	Mean result					Method
	Daltex RoofTX Optima	Daltex RoofTX Ultra	Daltex RoofTX	Daltex RoofTX Maxi	Daltex RoofTX Extra	
Mullen burst strength (kN·m <sup>-2</sup> )	438	438	459	–	–	BS 3137
Water vapour transmission (g·m <sup>-2</sup> ·day <sup>-1</sup> ) (25°C/75% RH)	1155	1367	1388	1387	1007	BS 3177
Vapour resistance (MN·s·g <sup>-1</sup> )	0.20	0.15	0.15	0.15	0.18	BS 3177
Low temperature flexibility (°C)	–	–	–40	–40	–40	EN 1109
Dimensional stability (%)						EN 1107-2
longitudinal	–1.27	–0.95	–	0.00	–0.42	
transverse	0.00	–0.22	–	0.00	–0.18	
Slip resistance (coefficient of friction)						T1/10 <sup>(1)</sup>
dry	–	–	0.97	–	–	
wet	–	–	0.65	–	–	
Hydrostatic head (cm)	598	540	–	589	–	BS EN 20811
Resistance to water penetration						BS EN 1928 <sup>(2)</sup>
unaged	W1	W1	W1	W1	W1	
aged <sup>(3)</sup>	W1	W1	W1	W1	W1	
Spray test	–	–	pass	–	–	T1/15 <sup>(1)</sup>
Resistance to streaming water						MOAT 69 : 4.2.2
supported	pass	pass	–	–	–	
unsupported	pass	pass	–	–	–	
Resistance to wind loads (kPa) <sup>(4)</sup>						MOAT 69 : 4.2.1
batten spacing 350 mm	0.5	1.0	0.5	0.5	2.0	
batten spacing 330 mm	0.5	1.0	–	1.0	2.5	
batten spacing 300 mm	1.0	2.0	1.0	1.0	2.5	
batten spacing 250 mm	2.0	2.5	2.5	2.5	–	
batten spacing 200 mm	2.5	–	2.5	–	–	

(1) BBA test method.

(2) As modified in accordance with BS EN 13859-1 : 2005.

(3) UVA aged for 336 hrs at 50°C/heat aged for 90 days at 70±2°C.

(4) Test carried out using 25 mm thick battens and a 600 mm rafter spacing.

## 17 Investigations

17.1 Using computer modelling cold non-ventilated roofs were analysed for risk of condensation.

17.2 The manufacturing process was assessed, including the method adopted for quality control, and details were obtained of the quality and composition of the materials used.

## Bibliography

- BS 3137 : 1972 *Methods for determining the bursting strength of paper and board*
- BS 3177 : 1959 *Method for determining the permeability to water vapour of flexible sheet materials used for packaging*
- BS 5250 : 2002 *Code of practice for control of condensation in buildings*
- BS 5534 : 2003 *Code of practice for slating and tiling (including shingles)*
- BS 8000-6 : 1990 *Workmanship on building sites — Code of practice for slating and tiling of roofs and claddings*
- BS EN 1928 : 2000 *Flexible sheets for waterproofing — Bitumen, plastic and rubber sheets for roof waterproofing — Determination of watertightness*
- BS EN 1991-1-4 : 2005 *Eurocode 1 : Actions on structures — General actions — Wind actions*
- NA to BS EN 1991-1-4 : 2008 *UK National Annex to Eurocode 1 : Actions on structures — General actions — Wind actions*
- BS EN 13501-1 : 2002 *Fire classification of construction products and building elements. Classification using test data from reaction to fire tests*
- BS EN 13859-1 : 2005 *Flexible sheets for waterproofing — Definitions and characteristics of underlays — Underlays for discontinuous roofing*
- BS EN 12310-1 : 2000 *Flexible sheets for waterproofing — Determination of resistance to tearing (nail shank)— Bitumen sheets for roof waterproofing*
- BS EN 12311-1 : 2000 *Flexible sheets for waterproofing — Determination of tensile properties — Bitumen sheets for roof waterproofing*
- BS EN 20811 : 1992 *Textiles — Determination of resistance to water penetration — Hydrostatic pressure test*
- EN 1107-2 : 2001 *Flexible sheets for waterproofing — Determination of dimensional stability — Plastic and rubber sheet for roof waterproofing*
- EN 1109 : 1999 *Flexible sheets for waterproofing — Bitumen sheets for roof waterproofing — Determination of flexibility at low temperature*
- MOAT No 27 : 1983 *General Directive for the Assessment of Roof Waterproofing Systems*
- MOAT No 69 : 2004 *UEAtc Technical Report for the Assessment of Discontinuous Roofing Underlay Systems*

## 18 Conditions

18.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is granted only to the company, firm or person named on the front page — no other company, firm or person may hold or claim any entitlement to this Certificate
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English law.

18.2 Publications and documents referred to in this Certificate are those that the BBA deems to be relevant at the date of issue or re-issue of this Certificate and include any: Act of Parliament; Statutory Instrument; Directive; Regulation; British, European or International Standard; Code of Practice; manufacturers' instructions; or any other publication or document similar or related to the aforementioned.

18.3 This Certificate will remain valid for an unlimited period provided that the product/system and the manufacture and/or fabrication including all related and relevant processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

18.4 In granting this Certificate, the BBA is not responsible for:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- individual installations of the product/system, including the nature, design, methods and workmanship of or related to the installation
- the actual works in which the product/system is installed, used and maintained, including the nature, design, methods and workmanship of such works.

18.5 Any information relating to the manufacture, supply, installation, use and maintenance of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used and maintained. It does not purport in any way to restate the requirements of the Health & Safety at Work etc Act 1974, or of any other statutory, common law or other duty which may exist at the date of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care. In granting this Certificate, the BBA does not accept responsibility to any person or body for any loss or damage, including personal injury, arising as a direct or indirect result of the manufacture, supply, installation, use and maintenance of this product/system.