

IKO PLC

Appley Lane North
Appley Bridge
Wigan
Lancashire WN6 9AB

Tel: 0844 412 7207 Fax: 0844 412 7208
e-mail: info@ikogroup.co.uk
website: www.ikogroup.co.uk



Agrément Certificate
09/4700
Product Sheet 1

ROOFSHOP BREATHER MEMBRANE

FOR USE IN WARM NON-VENTILATED AND COLD VENTILATED ROOFS

PRODUCT SCOPE AND SUMMARY OF CERTIFICATE

This Certificate relates to Roofshop Breather Membrane for use in warm non-ventilated and cold ventilated pitched roof systems.

AGRÉMENT CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness — as part of a complete roof, the product will resist the passage of water and wind-blown snow and dust into the interior of the building (see section 5).

Risk of condensation — the product is regarded as a low water vapour resistance (Type LR) underlay and can be used as part of a warm non-ventilated and cold ventilated pitched roof system (see section 6).

Wind loading — when installed on appropriately spaced battens the product's physical properties are deemed adequate to resist the wind loads imposed on the underlay. The product will reduce the wind uplift forces acting on the roof covering (see section 7).

Strength — the product has adequate strength to resist the loads associated with the installation of the roof (see section 8).

Durability — under the normal conditions found in a roof space the product will have a service life comparable to a traditional roof tile underlay (see section 11).

The BBA has awarded this Agrément Certificate to the company named above for the product described herein. The product has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Simon Wroe
Head of Approvals — Materials

Greg Cooper
Chief Executive

Date of First issue: 16 December 2009

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2009

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk

Regulations

In the opinion of the BBA, Roofshop Breather Membrane, if used in accordance with the provisions of this Certificate, will meet or contribute to meeting the relevant requirements of the following Building Regulations:



The Building Regulations 2000 (as amended) (England and Wales)

Requirement:	C2(b)	Resistance to moisture
Comment:		The product will contribute to a roof meeting this Requirement. See section 5.1 of this Certificate.
Requirement:	Regulation 7	Materials and workmanship
Comment:		The product is an acceptable material. See section 11 the <i>Installation</i> part of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation:	8(1)	Fitness and durability of materials and workmanship
Comment:		The product can contribute to a construction satisfying this Regulation. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation:	9	Building standards – construction
Standard:	3.10	Precipitation
Comment:		The product will contribute to a roof satisfying clauses 3.10.1 ⁽¹⁾ and 3.10.8 ⁽¹⁾ of this Standard. See section 5.1 of this Certificate.
Regulation:	12	Building standards – conversions
Comment:		All comments given for this product under Regulation 9, also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2000 (as amended)

Regulation:	B2	Fitness of materials and workmanship
Comment:		The product is an acceptable material. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation:	C4(b)	Resistance to ground moisture and weather
Comment:		The product will contribute to a roof satisfying this Regulation. See section 5.1 of this Certificate.

Construction (Design and Management) Regulations 2007

Construction (Design and Management) Regulations (Northern Ireland) 2007

Information in this Certificate may assist the client, CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

See section: 1 *Description* (1.2).

Non-regulatory Information

NHBC Standards 2008

NHBC accepts the use of Roofshop Breather Membrane, when installed and used in accordance with this Certificate, as meeting Technical Requirement R3 in relation to *NHBC Standards*, Chapter 7.2 *Pitched roofs* (ie ridge or high level ventilation is not required).

General

Roofshop Breather Membrane is marketed by SIG Roofing Supplies Group, Harding Way, St Ives, Cambridgeshire PE27 3YJ, Tel: 01480 46777, Fax: 01480 300269, e-mail: info@roofshop.co.uk website: www.roofshop.co.uk

Technical Specification

1 Description

1.1 Roofshop Breather Membrane is a thermally-bonded film laminate composite made of polyolefins.

1.2 The product has the following nominal characteristics:

Thickness (mm)	0.40
Weight per unit area ($\text{g}\cdot\text{m}^{-2}$)	100
Roll length (m)	50
Roll width (m)	1.0 and 1.5
Colour	
upper	grey
lower	grey

1.3 Quality control checks are carried out on the incoming materials, during production and on the finished product. Quality control checks on the finished product include:

- dimension checks
- weight
- water penetration
- tear strength
- tensile strength and elongation
- water vapour permeability
- dimensional stability.

2 Delivery and site handling

2.1 Rolls are delivered to site in packages that carry a label bearing the marketing company's name, the grade identification and the BBA identification mark including the number of this Certificate.

2.2 The rolls should be stored flat on their sides, on a smooth, clean, dry surface, under cover and protected from sunlight.

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Roofshop Breather Membrane.

Design Considerations


3 Use

Roofshop Breather Membrane is satisfactory for use as a fully supported or unsupported underlay in tiled and slated pitched roofs constructed in accordance with the relevant Clauses of BS 5534 : 2003.

4 Practicability of installation

The product is designed to be installed by competent slaters/tilers, experienced with this product.

5 Weathertightness

 5.1 Tests indicate that the product will resist the passage of water, wind-blown snow and dust into the interior of a building, under all conditions to be found in a roof constructed in accordance with the relevant Clauses of BS 5534 : 2003.

5.2 The product resists penetration of liquid water and consequently may be used as temporary waterproofing prior to the installation of slates or tiles. The period of such use should, however, be kept to a minimum. Advice should be sought from the Certificate holder (see section 16, Table for *Physical properties — general*).

6 Risk of condensation

6.1 For design purposes, the product's water vapour resistance may be taken as not more than $0.25 \text{ MN}\cdot\text{s}\cdot\text{g}^{-1}$, and for roofs designed in accordance with BS 5534 : 2003 or BS 5250 : 2002, Section 8.4, it may be regarded as a Type LR membrane.

6.2 In common with all roofs, care must be taken in the overall design and installation to minimise the risk of water vapour coming into contact with cold parts of the construction. Factors to be considered and minimised include, moisture diffusion through the ceiling, infiltration through unsealed openings/penetrations in the ceiling and services evaporating or venting moisture into cold spaces.

6.3 The risk of condensation is highest in new-build construction during the first heating period, where there is high moisture loading due to wet trades, such as in-situ cast concrete slabs or plaster. The risk of condensation diminishes as the building naturally dries out. See *BBA Information Bulletin No 1 — Roof Tile Underlays in Cold Roofs during the Drying-Out Period*.

Ceiling and insulation horizontal (cold roof)

6.4 Roofs designed and constructed in accordance with BS 5250 : 2002 will adequately limit the risk of interstitial condensation.

Ceiling and insulation inclined (warm roof)

6.5 For roofs with an insulated inclined ceiling, ventilation above or below the underlay will not be required provided that the passage of moisture by diffusion and by convection is controlled, eg, by a vapour control layer or a continuous envelope of insulation with a high vapour resistance.

Ceiling and insulation partially inclined (warm roof and cold roof)

6.6 Where an insulated ceiling only spans part of the roofline, resulting cold roof spaces should be ventilated in accordance with BS 5250 : 2002, Section 8.4.2.5 and 8.4.2.6.

7 Wind loading

7.1 Project design wind speeds should be determined and wind uplift forces calculated, in accordance with BS 6399-2 : 1997.

7.2 The product, when fully supported, has adequate resistance to wind uplift forces.

7.3 For a cold ventilated system, wind loading on the underlay should be calculated in accordance with BS 5534 : 2003, Section 5.5.2.7. For acceptable wind loads with specific batten spacings for the draped product, using a 25 mm deep tiling batten, see section 16, Table for *Physical properties — general*.

8 Strength

The product will resist the loads associated with installation of the roof (see section 16, Table for *Physical properties — directional*).

9 Properties in relation to fire

9.1 The product will have similar properties in relation to fire to those of traditional polyethylene roof tile underlays.

9.2 When the product is used unsupported, there is a risk that fire can spread if it is accidentally ignited during maintenance works, eg by a roofer's or plumber's torch. As with all types of underlay, care should be taken during building and maintenance to avoid the material becoming ignited.

9.3 When the product is used in a fully supported situation, the reaction to fire will be determined by the support.

10 Maintenance

As the product is confined within a roof system and has suitable durability (section 11) maintenance is not required. However, it must be ensured that damage occurring before enclosure is repaired (see section 14).

11 Durability



The product will be virtually unaffected by the normal conditions found in a roof space and will have a life comparable with that of traditional roof tile underlays, provided it is not exposed to sunlight for long periods (see section 12.4). Advice regarding exposure can be obtained from the Certificate holder.

Installation

12 General

12.1 Roofshop Breather Membrane must be installed and fixed in accordance with the Certificate holder's instructions, provisions of this Certificate and the relevant recommendations of BS 5534 : 2003 and BS 8000-6 : 1990. Installation can be carried out under all conditions normal to roofing work.

12.2 The product is installed with the coloured or printed side uppermost and lapped to shed water out and down the slope.

12.3 Overlaps must be provided with the minimum dimensions given in Table 1.

Roof pitch (°)	Horizontal lap (mm)		Vertical laps (mm)
	Not fully supported	Fully supported	
12.5 to 14	225	150	100
15 to 34	150	100	100
35+	100	75	100

12.4 Where possible, eaves guards should be used to protect the product from sunlight, and to direct water into the gutter.

12.5 Hips should be covered with a 600 mm wide strip of the product.

13 Procedure

Fully supported

13.1 The product may be used over sarking boards of softwood, C4 grade chipboard or water-resistant grade plywood or water-resistant grade OSB and either with continuous insulation or insulation placed between the rafters.

13.2 The product is secured to the support with counter battens at least 12 mm thick to create an air space between the product and the tiles for drainage and vapour dispersal. The counter battens are fixed with corrosion-resistant staples or galvanized clout nails as appropriate. Tiling battens are secured to the counter battens and rafters with appropriate fixings.

13.3 Care must be taken to minimise the risk of interstitial condensation as described in section 6.5 particularly for timber sarking which may be below the dew-point for extended periods during winter months.

Unsupported

13.4 The product, when installed as an unsupported system, is fixed in the traditional method for roof tile underlays, ie draped between the rafters.

14 Repair

Damage to the product can be repaired easily prior to the installation of slates or tiles by replacing the damaged areas, by patching and sealing correctly. Care should be taken to ensure that the watertightness of the roof is maintained.

15 Finishing

15.1 Detailing of abutments, verges and hips must be in accordance with the Certificate holder's instructions.

15.2 The tiling and slating must be carried out in accordance with the relevant Clauses of BS 5534 : 2003, BS 8000-6 : 1990 and the Certificate holder's instructions, especially when using tightly-jointed slates or tiles.

Technical Investigations

16 Tests

Samples of Roofshop Breather Membrane were obtained from the Certificate holder for testing. The results of the tests carried out by, or on behalf of, the BBA are summarised in Tables 2 and 3.

Table 2 Physical properties — directional

Test (units)	Mean results	Method ⁽¹⁾
Tensile strength (N per 50 mm)		BS EN 12311-1
unaged		
longitudinal	193	
transverse	152	
aged ⁽²⁾		
longitudinal	143	
transverse	133	
wet strength ⁽³⁾		
longitudinal	193	
transverse	148	
Elongation at break (%)		BS EN 12311-1
unaged		
longitudinal	31	
transverse	83	
aged ⁽²⁾		
longitudinal	26	
transverse	57	
wet strength ⁽³⁾		
longitudinal	29	
transverse	76	
Tear resistance (nail) (N)		BS EN 12310-1
unaged		
longitudinal	101	
transverse	114	

(1) The test documents are detailed in the *Bibliography*. Numbers in the table refer to sections/parts of the various documents.

(2) UVA aged for 336 hours at 50°C/heat aged for 90 days at (70±2)°C.

(3) Wet strength soak at 23°C for 24 hours — tested surface wet.

Table 3 Physical properties —general

Test (units)	Mean results	Method ⁽¹⁾
Water vapour transmission at 25°C/75% RH (g·m ⁻² ·day ⁻¹)	1348	BS 3177
Vapour resistance (MN·s·g ⁻¹)	0.15	BS 3177
Resistance to water penetration unaged aged ⁽³⁾	Class W1 Class W1	EN 1928 ⁽²⁾
Resistance to streaming water supported unsupported	pass pass	MOAT 69 : 4.2.2
Mullen burst strength (kN·m ⁻²)	338	BS 3137
Head of water (cm)	395	BS EN 20811
Resistance to wind loads (kPa) ⁽⁴⁾		MOAT 69 : 4.2.1
batten spacing 350 mm	0.5	
batten spacing 330 mm	1.0	
batten spacing 300 mm	1.0	
batten spacing 250 mm	2.5	
batten spacing 200 mm	—	

(1) The test documents are detailed in the *Bibliography*. Numbers in the table refer to sections/parts of the various documents.

(2) As modified in accordance with EN 13859-1 : 2005.

(3) UVA aged for 336 hours at 50°C/heat aged for 90 days at (70±2)°C.

(4) Test carried out using 25 mm thick battens and a 600 mm rafter spacing.

17 Investigations

17.1 The condensation risk in warm roof constructions, and specifically those containing sarking boards, incorporating the products was examined.

17.2 The manufacturing process was assessed, including the method adopted for quality control, and details were obtained of the quality and composition of the materials used.

17.3 Existing data for a product of similar composition was assessed for the following properties:

- dimensional stability
- slip resistance (dry and wet).

Bibliography

BS 3137 : 1972 *Methods for determining the bursting strength of paper and board*

BS 3177 : 1959 *Methods for determining the permeability to water vapour of flexible sheet materials used for packaging*

BS 5250 : 2002 *Code of practice for control of condensation in buildings*

BS 5534 : 2003 *Code of practice for slating and tiling (including shingles)*

BS 6399-2 : 1997 *Loading for buildings — Code of practice for wind loads*

BS 8000-6 : 1990 *Workmanship on building sites — Code of practice for slating and tiling of roofs and claddings*

BS EN 12310-1 : 2000 *Flexible sheets for waterproofing — Determination of resistance to tearing (nail shank)— Part 1 — Bitumen sheets for roof waterproofing*

BS EN 12311-1 : 2000 *Flexible sheets for waterproofing — Determination of tensile properties — Part 1 — Bitumen sheets for roof waterproofing*

BS EN 20811 : 1992 *Textiles — Determination of resistance to water penetration — Hydrostatic pressure test*

EN 1928 : 2000 *Flexible sheets for waterproofing — Bitumen, plastic and rubber sheets for roof waterproofing — Determination of watertightness*

EN 13859-1 : 2005 *Flexible sheets for waterproofing — Definitions and characteristics of underlays — Part 1 Underlays for discontinuous roofing*

MOAT No 69 : 2004 *UEAtc Technical Report for the Assessment of Discontinuous Roofing Underlay Systems*

18 Conditions

18.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is granted only to the company, firm or person named on the front page — no other company, firm or person may hold or claim any entitlement to this Certificate
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English law.

18.2 Publications and documents referred to in this Certificate are those that the BBA deems to be relevant at the date of issue or re-issue of this Certificate and include any: Act of Parliament; Statutory Instrument; Directive; Regulation; British, European or International Standard; Code of Practice; manufacturers' instructions; or any other publication or document similar or related to the aforementioned.

18.3 This Certificate will remain valid for an unlimited period provided that the product/system and the manufacture and/or fabrication including all related and relevant processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

18.4 In granting this Certificate, the BBA is not responsible for:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- individual installations of the product/system, including the nature, design, methods and workmanship of or related to the installation
- the actual works in which the product/system is installed, used and maintained, including the nature, design, methods and workmanship of such works.

18.5 Any information relating to the manufacture, supply, installation, use and maintenance of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used and maintained. It does not purport in any way to restate the requirements of the Health & Safety at Work etc Act 1974, or of any other statutory, common law or other duty which may exist at the date of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care. In granting this Certificate, the BBA does not accept responsibility to any person or body for any loss or damage, including personal injury, arising as a direct or indirect result of the manufacture, supply, installation, use and maintenance of this product/system.

