



# CERTIFICATE OF CONFORMITY

No CC/0045

## Products

### Deceuninck Heritage 2800 Series Inward/Outward Opening PVC-U French Door System

## Manufacturer

Building Product Solutions Ltd  
Unit 30, Commercial Road  
Rotherham  
South Yorkshire S63 9BL  
Tel: 01709 882 080 e-mail: [info@buildingproductsolutions.co.uk](mailto:info@buildingproductsolutions.co.uk)  
website: [www.buildingproductsolutions.co.uk](http://www.buildingproductsolutions.co.uk)

## Statement

Deceuninck Heritage 2800 Series inward/outward opening double-leaf French doors were tested to BS 6375 Parts 1, 2 and 3 and PAS 24 : 2016 Annexes A and B and found to comply (see *Limitations* for limitations of use).

## Classification

The door system is classified D.

## Material

Outer frame: 2833 reinforced with 2887 steel  
Leaf: 2891 reinforced with 2843/2847 steel  
Floating Mullion: 2835 reinforced with 2845 steel with aluminium adapter 2839  
Low threshold: 2978, 2977 and 2979 (open-out)  
2978, 2976 (open-in)  
Glazing bead: 2840  
Locking system: Maco C-TS or Yale Mantis 3  
Keeps: Maco C-TS or Yale Mantis 3  
Cylinder: Maco  
Hinges: Greenteq hybrid pin  
Handle: Greenteq lever/lever  
Glass: 28 mm double-glazed unit

## Limitations

Maximum size — 2150 mm (h) x 1800 mm (w)  
Double-glazed

## Performance

Air leakage (EN 12207) — Class 2  
Watertightness (EN 12208) — Class 4A or Class 3A with low threshold  
Wind loading (EN 12210) — Class A3  
Mechanical durability (EN 12400) — Class 2 medium duty  
Repeated opening and closing — Class 4 (master leaf) and class 1 (slave leaf)  
Thermal transmittance (EN 10077-2) — U value  $1.4 \text{ W}\cdot\text{m}^{-2}\cdot\text{K}^{-1}$

On behalf of the BBA

Hardy Giesler, Chief Executive Officer

Date: 14 June 2021

British Board of Agrément, Bucknalls Lane, Watford, Hertfordshire WD25 9BA

Tel: 01923 665300

e-mail: [clientservices@bbacert.co.uk](mailto:clientservices@bbacert.co.uk)

website: [www.bbacerts.co.uk](http://www.bbacerts.co.uk)

©2021